



# EC-Declaration of Conformity

We **MOLLET Füllstandtechnik GmbH**

Hans-Ulrich-Breymann-Str. 10  
D-74706 Osterburken  
Tel. +49 (0) 6291 64400 Fax +49 (0) 6291 9846

declare that the devices:

## Rotary blade level indicator

Type **DF..A3...** and **DF..A4...**

to which this declaration relates is in accordance with the following standards or other normative documents:

**Directive 94/9/EC** (Directive ATEX)

**Directive 89/336/EEC** (Directive EMC)

**Directive 73/23/EEC** (Electrical equipment designed for use within certain voltage limits)

and

**EN 50281-1-1:2000, EN 50014:1997+A1+A2,**

**EN 50018:2000+A1, EN 50019:2000,**

**EN 1127-1:1997, EN 13463-1:2001, prEN 13463-5:2003,**

**EN 50281-1-2, CLC/TR 50404:2003**

**EN 55022, EN 55024, EN 61000-6-2**

**EN 1050, EN ISO 12100-1, EN ISO 12100-2,**

**EN 61010-1, EN 60204-1:1997**

The Essential Health and Safety Requirements are assured by compliance with the directive and observance of the normative documents.

The marking of the equipment includes the following:

for the electrical part:

**CE** <sub>0032</sub> **Ex** II 1D2G/2GD EEx de IIB T6 T 70 °C IP 66  
-20 °C ≤ T<sub>a</sub> ≤ +60 °C

EC-type-examination Certificate Number **IBExU04ATEX1033X**

for the non-electrical part:

**CE** <sub>0032</sub> **Ex** II 1D2G/2GD c IIB T X

EC-type-examination Certificate Number **IBExU04ATEX1001X**

Osterburken, March 04, 2004

Production quality assurance:

**Qualitäts-  
Management**

Regelmäßige freiwillige  
Überwachung nach  
DIN EN ISO 9001:2000



**Qualitäts-  
Sicherungs-  
System**

Anerkennung nach  
Richtlinie 94/9/EG



Wolfgang Hageleit